

बिड दस्तावेज़ / Bid Document

बिड विवरण / Bid Details	
बिड बंद होने की तारीख/समय / Bid End Date/Time	07-10-2025 15:00:00
बिड खुलने की तारीख/समय / Bid Opening Date/Time	07-10-2025 15:30:00
बिड पेशकश वैधता (बंद होने की तारीख से) / Bid Offer Validity (From End Date)	120 (Days)
मंत्रालय/राज्य का नाम / Ministry/State Name	Ministry Of Railways
विभाग का नाम / Department Name	Railways Public Sector Undertakings
संगठन का नाम / Organisation Name	Indian Railway Catering And Tourism Corporation Limited
कार्यालय का नाम / Office Name	Corporate Office
कुल मात्रा / Total Quantity	3
वस्तु श्रेणी / Item Category	Higher Rating Diesel Generating Sets (1010 kVA and above) (Q3)
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) / Minimum Average Annual Turnover of the bidder (For 3 Years)	4 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का) / OEM Average Turnover (Last 3 Years)	4 Lakh (s)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष / Years of Past Experience Required for same/similar service	3 Year (s)
टर्नओवर के लिए एमएसई को छूट प्राप्त है / MSE Exemption for Turnover	Yes Partial Turn over value - 1 (in lakhs)
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Exemption for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़ / Document required from seller	Experience Criteria, Past Performance, Bidder Turnover, OEM Authorization Certificate, OEM Annual Turnover, Additional Doc 1 (Requested in ATC), Additional Doc 2 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer

बिड विवरण/Bid Details	
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	2
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
विगत प्रदर्शन /Past Performance	60 %
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/RA Qualification Rule	50% Lowest Priced Technically Qualified Bidders
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	Higher Rating Diesel Generating Sets (1010 kVA and above)
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/Evaluation Method	Item wise consignee wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
Schedule 1 ईएमडी राशि/EMD Amount (In INR)	504900
Schedule 2 ईएमडी राशि/EMD Amount (In INR)	364490
Schedule 3 ईएमडी राशि/EMD Amount (In INR)	364490

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने हैं। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). The EMD Amount will be applicable for each schedule/group selected during Bid creation.

(c). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

JGM/Finance

Corporate Office, Railways Public Sector Undertakings, Indian Railway Catering and Tourism Corporation Limited, Ministry of Railways (Irctc)

विभाजन/Splitting

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	Yes
--	-----

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
---	-----

1. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be exempted from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking exemption from Turnover, shall upload the supporting documents to prove his eligibility for exemption.
2. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
3. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value

should meet this criterion.

4. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

5. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

6. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

7. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

8. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 60% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

9. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE

L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

एक्सेल में अपलोड किए जाने की आवश्यकता /Excel Upload Required :

Price Break Up Sheet - [1758018661.xlsx](#)

मूल्यांकन विधि(मदवार मूल्यांकन विधि) / **Evaluation Method** (Item Wise Consignee Wise Evaluation Method)

Contract will be awarded schedulewise and the determination of L1 will be done separately for each schedule. The details of item-consignee combination covered under each schedule are as under:

मूल्यांकन अनुसूचियां / Evaluation Schedules	वस्तु/श्रेणी / Item/Category	Consignee Address	मात्रा / Qua ntity
Schedule 1	Higher Rating Diesel Generating Sets (1010 Kva And Above)	RailNeer Plant, Near Plot no.B-115, Additional MIDC, Anand Nagar. Ambarnath-421506 421506	1
Schedule 2	Higher Rating Diesel Generating Sets (1010 Kva And Above)	4th Floor, Biscomaun Tower, West Gandhi Maidan, Patna- 800001 800001	1
Schedule 3	Higher Rating Diesel Generating Sets (1010 Kva And Above)	Rail Neer Packaged Drinking Water Bottling Plant, Palur Railway Station, Palur Post, Chengalpattu Taluk, Kanchipuram District - 603101 Tamil Nadu 603101	1

Higher Rating Diesel Generating Sets (1010 KVA And Above) (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ENGINE	Type of Engine cooling	Radiator Cooled, Heat Exchnager Cooled
	Type of governer	Electronic, Electronic-Isochronous Or higher
	Class of governer	A1, A0 Or higher
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (kVA)	1250
ALTERNATOR	Alternator Voltage Rating	415, 3300, 11000 (Volt)
	Wiring System	4 Wire
	Voltage Regulation Grade upto 1250 kVA	NA, VG 1, VG 2, VG 3 Or higher
	Voltage Regulation Grade above 1250 kVA	NA, G 1, G 2, G 3 Or higher
CONTROL PANEL	Control Panel	AMF

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Location of Control Panel	Outside the Acoustic Enclosure
ACOUSTIC ENCLOSURE	Acoustic Enclosure inclusive in the scope of supply	With Acoustic Enclosure, Without Acoustic Enclosure
	"Sheet Thickness of acoustic enclosure (May Specify '0' in case of without acoustic enclosure)"	1.6 mm, 1.8 mm, 2.0 mm Or higher
FUEL TANK	Number of Fuel Tanks supplied with each DG Set (inclusive in the scope of supply)	0, 1, 2 Or higher
SCOPE OF INSTALLATION	Installation	With Installation - inclusive in the scope of supply, Without Installation(Required technical input and supervision will be provided to buyer installation team)
	Scope of installation for Diesel Generating Set(Part-1) when offered by the vendor - inclusive in the scope of supply	Scope of installation when offered by the seller (With Installation - inclusive in the scope of supply) :- a) Installation of DG Set when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of DG Set and its constituent parts shall be generally conforming to CPWD General specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of PCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the DG set. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller., Not Applicable as Installation not offered
	Scope of installation for Diesel Generating Set (Part 2)when offered by the vendor - inclusive in the scope of supply	c) Supply, laying and termination of interconnecting power and control cable between Seller's supplied equipments shall be done by the seller. The interconnecting cable supplied along with each DG Set shall be of suitable current rating and shall be sufficient for a distance of 60 metres. For DG Sets having voltage rating upto 415 Volts, the cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For DG Sets having voltage rating from 3300 Volts upto and including 33000 Volts, the cable supplied shall be ISI marked XLPE, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with copper conductor having XLPE insulation, suitable for rated voltage from 3.3 kV upto and including 33 kV and conforming to IS: 7908 (Part-2) latest., Not Applicable as Installation not offered

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Scope of installation for Diesel Generating Set (Part 3)when offered by the vendor - inclusive in the scope of supply	d) Construction of suitable earthing station and necessary connections shall be done by the seller. All the materials / labour required for construction of earthing station shall be supplied by the seller. The total number of earthing pits/stations shall be 4, i.e., 2 for neutral and 2 for body-earthing. Netutral earthing shall be done with copper Plate and Body earthing shall be done with G.I. plate / Copper. The consignee should choose installation site in such a way that the earthing stations can be made within 10 metres of the DG set. Earthing station shall be typically constructed as per prevalent standard practices and shall be generally conforming to CPWD General specification for Electrical Works, Part - VII & Part - I - latest. e) Installation of Fuel Tank(s) including foundation / stand, where applicable, shall be done by the seller., Not Applicable as Installation not offered
	Above Scope of installation for Diesel Generating Set(Part-1 + Part-2 + Part-3) when offered by the vendor has been seen, read, understood and agreed to comply	Yes, Not Applicable as Installation not offered
WARRANTY & SERVICING	Warranty	12, 24 Or higher (month)
TEST REPORTS	Test report issuing authority for Engine Rating as per IS: 13018 latest / ISO 3046-latest	Engine Manufacturer, Witnessed by Central government/NABL/ILAC accrdited agency
	Availability of Type test report for Alternator from Central government/NABL/ILAC accrdited laboratory to prove conformity to the specifications	Yes, No

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Swapnil Moon	421506,RailNeer Plant, Near Plot no.B-115, Additional MIDC, Anand Nagar. Ambernath-421506	1	15

Higher Rating Diesel Generating Sets (1010 KVA And Above) (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ENGINE	Type of Engine cooling	Radiator Cooled, Heat Exchnager Cooled
	Type of governer	Electronic, Electronic-Isochronous Or higher
	Class of governer	A1, A0 Or higher
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (kVA)	1010
ALTERNATOR	Alternator Voltage Rating	415, 3300, 11000 (Volt)
	Wiring System	4 Wire, 6 Wire
	Voltage Regulation Grade upto 1250 kVA	NA, VG 1, VG 2, VG 3 Or higher
	Voltage Regulation Grade above 1250 kVA	NA, G 1, G 2, G 3 Or higher
CONTROL PANEL	Control Panel	Manual, AMF
	Location of Control Panel	Inside the Acoustic Enclosure, Outside the Acoustic Enclosure
ACOUSTIC ENCLOSURE	Acoustic Enclosure inclusive in the scope of supply	With Acoustic Enclosure, Without Acoustic Enclosure
FUEL TANK	Number of Fuel Tanks supplied with each DG Set (inclusive in the scope of supply)	0, 1, 2 Or higher
SCOPE OF INSTALLATION	Installation	With Installation - inclusive in the scope of supply, Without Installation(Required technical input and supervision will be provided to buyer installation team)
	Scope of installation for Diesel Generating Set(Part-1) when offered by the vendor - inclusive in the scope of supply	Scope of installation when offered by the seller (With Installation - inclusive in the scope of supply) :- a) Installation of DG Set when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of DG Set and its constituent parts shall be generally conforming to CPWD General specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of PCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the DG set. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller., Not Applicable as Installation not offered

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Scope of installation for Diesel Generating Set (Part 2)when offered by the vendor - inclusive in the scope of supply	c) Supply, laying and termination of interconnecting power and control cable between Seller's supplied equipments shall be done by the seller. The interconnecting cable supplied along with each DG Set shall be of suitable current rating and shall be sufficient for a distance of 60 metres. For DG Sets having voltage rating upto 415 Volts, the cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For DG Sets having voltage rating from 3300 Volts upto and including 33000 Volts, the cable supplied shall be ISI marked XLPE, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with copper conductor having XLPE insulation, suitable for rated voltage from 3.3 kV upto and including 33 kV and conforming to IS: 7908 (Part-2) latest., Not Applicable as Installation not offered
	Scope of installation for Diesel Generating Set (Part 3)when offered by the vendor - inclusive in the scope of supply	d) Construction of suitable earthing station and necessary connections shall be done by the seller. All the materials / labour required for construction of earthing station shall be supplied by the seller. The total number of earthing pits/stations shall be 4, i.e., 2 for neutral and 2 for body-earthing. Netutral earthing shall be done with copper Plate and Body earthing shall be done with G.I. plate / Copper. The consignee should choose installation site in such a way that the earthing stations can be made within 10 metres of the DG set. Earthing station shall be typically constructed as per prevalent standard practices and shall be generally conforming to CPWD General specification for Electrical Works, Part - VII & Part - I - latest. e) Installation of Fuel Tank(s) including foundation / stand, where applicable, shall be done by the seller., Not Applicable as Installation not offered
	Above Scope of installation for Diesel Generating Set(Part-1 + Part-2 + Part-3) when offered by the vendor has been seen, read, understood and agreed to comply	Yes, Not Applicable as Installation not offered
WARRANTY & SERVICING	Warranty	12, 24 Or higher (month)
TEST REPORTS	Test report issuing authority for Engine Rating as per IS: 13018 latest / ISO 3046-latest	Engine Manufacturer, Witnessed by Central government/NABL/ILAC accridited agency

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Availability of Type test report for Alternator from Central government/NABL/ILAC accredited laboratory to prove conformity to the specifications	Yes, No

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Chetan Anand	800001,4th Floor, Biscomaun Tower, West Gandhi Maidan, Patna-800001	1	15

Higher Rating Diesel Generating Sets (1010 KVA And Above) (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ENGINE	Type of Engine cooling	Radiator Cooled, Heat Exchnager Cooled
	Type of governer	Electronic, Electronic-Isochronous Or higher
	Class of governer	A1, A0 Or higher
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (kVA)	1010, 1250, 1500, 1750, 2000, 2250, 3000
ALTERNATOR	Alternator Voltage Rating	415, 3300, 11000 (Volt)
	Wiring System	4 Wire, 6 Wire
	Voltage Regulation Grade upto 1250 kVA	NA, VG 1, VG 2, VG 3 Or higher
	Voltage Regulation Grade above 1250 kVA	NA, G 1, G 2, G 3 Or higher
CONTROL PANEL	Control Panel	Manual, AMF
	Location of Control Panel	Inside the Acoustic Enclosure, Outside the Acoustic Enclosure

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ACOUSTIC ENCLOSURE	Acoustic Enclosure inclusive in the scope of supply	With Acoustic Enclosure, Without Acoustic Enclosure
FUEL TANK	Number of Fuel Tanks supplied with each DG Set (inclusive in the scope of supply)	0, 1, 2 Or higher
SCOPE OF INSTALLATION	Installation	With Installation - inclusive in the scope of supply, Without Installation(Required technical input and supervision will be provided to buyer installation team)
	Scope of installation for Diesel Generating Set(Part-1) when offered by the vendor - inclusive in the scope of supply	Scope of installation when offered by the seller (With Installation - inclusive in the scope of supply) :- a) Installation of DG Set when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of DG Set and its constituent parts shall be generally conforming to CPWD General specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of PCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the DG set. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller., Not Applicable as Installation not offered
	Scope of installation for Diesel Generating Set (Part 2)when offered by the vendor - inclusive in the scope of supply	c) Supply, laying and termination of interconnecting power and control cable between Seller's supplied equipments shall be done by the seller. The interconnecting cable supplied along with each DG Set shall be of suitable current rating and shall be sufficient for a distance of 60 metres. For DG Sets having voltage rating upto 415 Volts, the cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For DG Sets having voltage rating from 3300 Volts upto and including 33000 Volts, the cable supplied shall be ISI marked XLPE, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with copper conductor having XLPE insulation, suitable for rated voltage from 3.3 kV upto and including 33 kV and conforming to IS: 7908 (Part-2) latest., Not Applicable as Installation not offered

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Scope of installation for Diesel Generating Set (Part 3)when offered by the vendor - inclusive in the scope of supply	d) Construction of suitable earthing station and necessary connections shall be done by the seller. All the materials / labour required for construction of earthing station shall be supplied by the seller. The total number of earthing pits/stations shall be 4, i.e., 2 for neutral and 2 for body-earthing. Netutral earthing shall be done with copper Plate and Body earthing shall be done with G.I. plate / Copper. The consignee should choose installation site in such a way that the earthing stations can be made within 10 metres of the DG set. Earthing station shall be typically constructed as per prevalent standard practices and shall be generally conforming to CPWD General specification for Electrical Works, Part - VII & Part - I - latest. e) Installation of Fuel Tank(s) including foundation / stand, where applicable, shall be done by the seller., Not Applicable as Installation not offered
	Above Scope of installation for Diesel Generating Set(Part-1 + Part-2 + Part-3) when offered by the vendor has been seen, read, understood and agreed to comply	Yes, Not Applicable as Installation not offered
WARRANTY & SERVICING	Warranty	12, 24 Or higher (month)
TEST REPORTS	Test report issuing authority for Engine Rating as per IS: 13018 latest / ISO 3046-latest	Engine Manufacturer, Witnessed by Central government/NABL/ILAC accridited agency
	Availability of Type test report for Alternator from Central government/NABL/ILAC accridited laboratory to prove conformity to the specifications	Yes, No

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Munikarthik Mj	603101,Rail Neer Packaged Drinking Water Bottling Plant, Palur Railway Station, Palur Post, Chengalpattu Taluk, Kanchipuram District - 603101 Tamil Nadu	1	15

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Generic

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

3. Scope of Supply

Scope of supply (Bid price to include all cost components) : Supply Installation Testing Commissioning of Goods and Training of operators and providing Statutory Clearances required (if any)

4. Forms of EMD and PBG

Bidders can also submit the EMD with Payment online through RTGS / internet banking in Beneficiary name

IRCTC INFRA AND RAIL NEER

Account No.

2121245632441212

IFSC Code

AUBL0002456

Bank Name

AU Small Finance Bank Ltd.

Branch address

24, Ring Road, Lajpat Nagar IV, Delhi 110024

Bidder to indicate bid number and name of bidding entity in the transaction details field at the time of on-line transfer. Bidder has to upload scanned copy / proof of the Online Payment Transfer along with bid.

5. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में

भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---